

Certificate

No. c7795a-23

Customer:

EFB Elektronik GmbH
Striegauer Straße 1
33719 Bielefeld, Germany

Class Ea

Test sample(s):

data cable:

CABLE CAT6A F/FTP 4X2XAWG23 LSZH WHITE

Part no.: DK-ICD6AFFW.500-V1 (simplex); DK-ICD6AFFDXW.500-V1 (Duplex)

connecting hardware:

CONNECTOR CAT6A STP TOOLLESS JACK

Part no.: DK-KS6ASLP

Applied standard(s):

ISO/IEC 11801-1 Ed.1.0 (2017-11)

Result(s):

The sample meets the limits of the specified standards and regulations with respect to the parameters indicated above.

2 Connector Permanent Link, Copper, Class Ea

GHMT Type Approval

The test results which were determined in the course of the measurement refer to the submitted specimen. Any future technical modifications of the verified products are subject to the responsibility of the manufacturer.

This Certificate refers to the comprehensive test report no. **R7795a-23** and shall only be applicable in conjunction with the test report. This certificate is valid 24 months after date of testing.

Bexbach, 31.01.2023



Dirk Wilhelm, engineer
(Chairman of the Managing Board)



Test laboratory accredited by DAkkS in accordance with DIN EN ISO/IEC 17025:2018.
The accreditation is valid for the test methods listed in certificate **D-PL-17559-01-00**.

GHMT AG

In der Kolling 320
66450 Bexbach / Germany

P.O. box 11 16
66442 Bexbach / Germany

T: +49 6826 92 28-0
F: +49 6826 92 28-290

info@ghmt.de
www.ghmt.de

**RELIABILITY IN TOTAL
REQUIRES ACCURACY IN DETAIL.**