

Zertifikat

Nr. z7659a-22

Auftraggeber:

EFB Elektronik GmbH
Striegauer Straße 1
33719 Bielefeld, Deutschland

Klasse E**Prüfling(e):**

Symmetrisches Kupferkabel:
CABLE CAT6 U/UTP 4X2XAWG23 LSZH WHITE SIMPLEX
CABLE CAT6 U/UTP 4X2XAWG23 LSZH WHITE DUPLEX
Art.-Nr.: DK-ICD6UW.305-V1; DK-ICD6UW.500-V1; DK-ICD6UW.500-V1

Steckverbinder:

CONNECTOR CAT6 UTP TOOLLESS JACK
Art.-Nr.: DK-KS6UW (white); DK-KS6UB (Black)

Bewertungsstandard(s):

ISO/IEC 11801-1 Ed.1.0 (2017-11)

Resultat:

Der Prüfling hält bei den im Prüfbericht genannten Prüfparametern die Grenzwerte der besagten Bewertungsstandards ein.

2 Connector Permanent Link, Kupfer, Klasse E

GHMT Type Approval

Die bei der Prüfung ermittelten Ergebnisse beziehen sich auf den beschriebenen und vom Auftraggeber vorgelegten Prüfling. Zukünftige technische Änderungen der geprüften Produkte unterliegen dem Verantwortungs- bereich der Hersteller.

Dieses Zertifikat verweist auf den ausführlichen Prüfbericht **Nr. R7659a-22** und ist nur in Verbindung mit diesem gültig. Dieses Zertifikat ist nach Prüfdatum 24 Monate gültig.

Bexbach, 14.11.2022



Dipl.-Ing. Dirk Wilhelm
(Vorstandsvorsitzender)

**GHMT AG**

In der Kolling 320
D-66450 Bexbach

Postfach 11 16
D-66442 Bexbach

T: +49 6826 92 28-0
F: +49 6826 92 28-290

info@ghmt.de
www.ghmt.de

**HOCHVERFÜGBARKEIT IM GANZEN
BEDINGT PRÄZISION IM DETAIL.**

Certificate

No. c7659a-22

Customer:

EFB Elektronik GmbH
Striegauer Straße 1
33719 Bielefeld, Germany

Class E

Test sample(s):

data cable:

CABLE CAT6 U/UTP 4X2XAWG23 LSZH WHITE SIMPLEX

CABLE CAT6 U/UTP 4X2XAWG23 LSZH WHITE DUPLEX

Part no.: DK-ICD6UW.305-V1; DK-ICD6UW.500-V1; DK-ICD6UW.500-V1

connecting hardware:

CONNECTOR CAT6 UTP TOOLLESS JACK

Part no.: DK-KS6UW (white); DK-KS6UB (Black)

Applied standard(s):

ISO/IEC 11801-1 Ed.1.0 (2017-11)

Result(s):

The sample meets the limits of the specified standards and regulations with respect to the parameters indicated above.

2 Connector Permanent Link, Copper, Class E

GHMT Type Approval

The test results which were determined in the course of the measurement refer to the submitted specimen. Any future technical modifications of the verified products are subject to the responsibility of the manufacturer.

This Certificate refers to the comprehensive test report **no. R7659a-22** and shall only be applicable in conjunction with the test report. This certificate is valid 24 months after date of testing.

Bexbach, 14.11.2022



Dirk Wilhelm, engineer
(Chairman of the Managing Board)



*Test laboratory accredited by DAkkS in accordance with DIN EN ISO/IEC 17025:2018.
The accreditation is valid for the test methods listed in certificate D-PL-17559-01-00.*

GHMT AG

In der Kolling 320
66450 Bexbach / Germany

P.O. box 11 16
66442 Bexbach / Germany

T: +49 6826 92 28-0
F: +49 6826 92 28-290

info@ghmt.de
www.ghmt.de

**RELIABILITY IN TOTAL
REQUIRES ACCURACY IN DETAIL.**